

**From:** Amanda B. White  
**Sent:** Friday, July 9, 2021 2:54 PM  
**To:** Estaban Herrera  
**Cc:** Ruben Alayon-Gonzalez; Carol Johnson; Curry Jones; Brent Larsen; Lemon, Shelly, NMENV; LucasKamat, Susan, NMENV; Dean, Levi, NMENV; Emily M. Day; Jennifer Von Rohr; Cheryl Rodriguez; Karly B. Rodriguez; Shannon M. Smith; Audrey Krehlik; Pamela T. Maestas; William Alexander  
**Subject:** N3B 24-hour notice for MTAL exceedances in validated data – 07-09-2021  
**Attachments:** SWTS\_MTAL\_24hour\_notification\_run\_18278\_\_ran07\_09\_2021\_\_669251330\_CHQ-SMA-1.02.pdf

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

Dear Mr. Herrera,

This notification is being made per the requirement in the NPDES Individual Permit (Permit # NM0030759) regarding exceedances of maximum target action levels (MTALs) in storm water samples for applicable pollutants. The exceedances occurred at the following Site Monitoring Areas (SMAs): CHQ-SMA-1.02. The auto-validated sampling data was received in the EIM chemistry data view on 07/09/2021. The automated data validation did not identify any deficiencies.

Please see attachments:

SWTS\_MTAL\_24hour\_notification\_run\_18278\_\_ran07\_09\_2021\_\_669251330\_CHQ-SMA-1.02.pdf

Please let me know if you have any questions.

Please acknowledge receipt of this submittal by responding to this email.

Sincerely,

**Amanda White**

Program Manager / Watershed Monitoring and Technical Services  
critical subcontractor to **N3B ER Water Program**



*This message, including any attachments, may include privileged, confidential and/or inside information. Any distribution or use of this communication by anyone other than the intended recipient is strictly prohibited and may be unlawful. If you are not the intended recipient, please notify the sender by replying to this message and then delete it from your system.*

# IP 24-Hour Oral Exceedance MTAL Report

Jul. 09, 2021

**Permitted** Q002A

**SMA:** CHQ-SMA-1.02

**Associated Site** 33-004(h), 33-008(c), 33-011(d), 33-015

**Station:** SS210621

**Canyon:** Chaquehui Canyon

**Canyon-Specific  
Hardness (ug/l):** 30.00

**Collected:** May. 31, 2021

**Processed:** Jul. 09, 2021

**Oral Report:** Jul. 09, 2021

Suite	Analyte	Analyte
-------	---------	---------

INORGANIC

Cu

Copper

Sample ID	Std Result	UOM	MQL	MTAL	Std Result TAL Ratio	Lab Qual	Contact Flag	Contact Reason
WT_IPC-21-228788	5.20	ug/L	0.5	4.3	1.2093022		NQ	NQ

\_\_\_\_\_  
Stormwater Project Manager

\_\_\_\_\_  
Date